

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

| Permit #: PRPWFC20171319 | , Public Works | Infrastructure Permit - | Commercial |
|--------------------------|----------------|-------------------------|------------|
|--------------------------|----------------|-------------------------|------------|

LBP V-A

Address: 2900 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection: Outcome: Date:

DEI-ADA Inspection Steve Robbins Partial Friday, May

04, 2018

Informational

The ADA ramps at the corner of Independence and Jones Idustrial Dr. have been formed and are ADA compliant for the pre-pour. Matt Munger and I went to the site and let them know the cannot use a 4 ft. trunkated dome for a 5 ft. sidewalk. Steve Robbins 05/04/2018 3:50 PM

Comments: