

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20172757, Building Permit - Commercial

Address: 300 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Partial	Monday, May 07, 2018

Partial Correction

1	Misc	OK WHEN READY TO INSTALL SHEATHING TO FACADE VERTICAL FACE ABOVE SOFFIT ELEVATION.
		OK TO COVER WHEN READY LIGHT GAUGE STEEL FRAMING AT: SOFFITS AND VERTICAL FRAMING ABOVE HARBOR FREIGHT ENTRANCE; COLUMN WRAP AND BUMP-OUTS AT GRADE; "BUMP-OUT" PER DETAIL 1/A310; DECORATIVE COLUMN AT SE EXTERIOR CORNER OF BUILDING APPROVED; A204 8-9 SEE PLANS; AREA DUE WEST OF PLANET FITNESS TO CORNER; <b>[AT FRONT OF SPACE 306;</b>

Comments: