

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180476, Building Permit - Residential

Address: 1345 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Khanh Nguyen	Failed	Wednesday, May 09, 2018

Corrective Action Required

1	Misc	MIDDLE HOLE IS FILLED WITH WATER. THE OUTER HOLES HAVE DEBRIS IN THEM
---	------	--

Comments: