

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173808, Building Permit - Residential

Address: 4716 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:

Inspector:

Outcome:

Date:

Piers/Caissons

Khanh Nguyen

Passed

Friday, May 11, 2018

Inspection - Residential

Comments:

MAKE SURE TO REMOVE THE DIRT THAT FELL IN THE HOLE. IF YOU CANNOT REMOVE IT, THEN COMPACT THE DIRT DOWN USING NEARBY LONG STUD