

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20172433, Building Permit - Residential

Address: 4709 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|----------------------|
| All Rough Inspection - Residential | Khanh Nguyen | Failed | Friday, May 11, 2018 |

Corrective Action Required

| | | |
|---|------|--|
| 1 | Misc | -Anchor basement sill plates per code. **near rear bedroom door |
| | | -Triple lvl at bed 4 per plan **rewire circuit |
| | | -Fb basement wall space from furdawn ceiling space |
| | | **OK TO INSULATE |

| | | | |
|--|--------------|--------|----------------------|
| Electrical Service Inspection - Residential | Khanh Nguyen | Passed | Friday, May 11, 2018 |
|--|--------------|--------|----------------------|

Comments: