

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172757, Building Permit - Commercial

Address: 300 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Friday, May 11, 2018

Partial Correction

1 Misc

OK TO POUR WHEN READY TWO FOOTINGS PER SECTION 01/S4.7
AND SECTION 02/S4.1;

Partial Correction

2 Misc

**FOOTING AT 6A203: CONCRETE CONTRACTOR STATES WILL
FLOAT IN #6 MATS; NO VERTICAL BARS PER DRAWING**

Comments: