

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20180370, Building Permit - Commercial

Address: 1704 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Friday, May 11, 2018
Partial Correction			
1 Misc		AT BLDGS 100 & 300: OK TO TAPE, MUD AND FIRE-STOP*.	
		AT BLDG 200:	
		- OBTAIN WRITTEN DIRECTION FROM ARCHITECT REGARDING SOUTH END OF NEW CORRIDOR WALL THAT, CONTRARY TO DRAWING, DOES NOT CLOSE WITH EXISTING CROSSWALL.	
		- NO COMBUSTIBLE ELEMENTS(SUCH AS 2x4) MAY PENETRATE RATED WALL	
		- PLACE NO CEILING TILE BEFORE RATED WALLS AND ABOVE-CEILING SYSTEMS ARE APPROVED TO COVER	
		- HOLES/OPENINGS IN GWB TOO LARGE TO FIRE-CAULK MUST BE CLOSED WITH 5/8" GWB	
		- OPEN ENDS OF RATED WALL MUST BE CLOSED TO PRODUCE A CLOSED SYSTEM	

\*FIRE-STOP ONLY WITH MATERIALS LISTED FOR THE PURPOSE

Comments: