

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20173222, Building Permit - Commercial

Address: 4101 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - Commercial	Khanh Nguyen	Failed	Monday, May 14, 2018

Corrective Action Required

1	Misc	NEED TO CORRECT THE DRAINAGE SLOPE NEAR THE BUILDING. MIN 1/8" PER FT SLOPE. THE REST OF SEWER FROM GREASE/SAND INTERCEPTOR AND NORMAL WASTE SEWER LINES TO SEWER STUB CONNECTION-OK TO BACKFILL
---	------	---

Comments: