LEE'S SUMMIT

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRSITE20180252, Development - Site TAILOR MADE LANDING Address: 1600 SE HAMBLEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item: Inspection:	Inspector:	Outcome:	Date:
DEI-Fire Line - Hydrostatic Test Informational	John DiMauro	Passed	Tuesday, May 15, 2018
1 Winwater Works set up and performed the Hydro test for the fire line from the connection			

at the main to the building. I observed the gauge hold 200 psi for two hours.

Comments: