

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180023, Building Permit - Residential

Address: 408 SE WEISS CIR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Benisch	Failed	Friday, May 18, 2018

Comments: 1. FLASHING NEEDED IN STOVE AND FLUE SHAFT AREA
2. SAFETY GLAZING NEEDED FOR WINDOW LEADING TO 2ND FLOOR