



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

May 18, 2018

J E HEFNER CO
2614 MURPHY SCHOOL RD
GRAIN VALLEY, MO 64029

Permit No: PRCOM20181505
Project Title: LIVING WORD BIBLE CHURCH REMOTE CLASSROOM
Project Address: 1040 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064
Parcel Number: 43540012400000000
Location: RNG-31 TWP-48 SEC-08 2 AC IN A SQUARE OUT OF TH SE SE 1/4 DAF: BEG SE COR SE SE 1/4 TH N ALG E LI SD 1/4 295.16' TH W 295.16' TO A PT ON E ROW LI OF I-470 TH S ALG SD ROW LI 295.16' TH E 295.16' TO POB (EX PT IN RD)
Type of Work: NEW OTHER (COMMERCIAL)
Occupancy Group:
Description: REMOTE CLASSROOM ACCESSORY TO CHURCH

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Joe Dir

Rejected

1. 2012 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED:(verified at inspection)

Provide a minimum of one 2A-10BC fire extinguisher. the extinguisher is to be mounted on a normal path of travel close to an exit.

2. Building use

ACTION REQUIRED:

provide additional information about the following:

(1) building use

(2) potential occupant load

Additional conditions may apply pending information.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.