

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20172113, Public Works Infrastructure Permit - Commercial

B&B Theatre

Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Miscellaneous Inspection	Steve Robbins	Passed	Friday, May 18, 2018

Corrective Action Required

1 On the private side, just off the approach on Fascination , some of the curb and asphalt sunk about 6 inches. Olsen testing came out and decided that the rock that was hit during installation of the storm and sanitary made a path for the water to get to the area that sunk. They dug down about 10-12 ft. and installed rip-rap on the bottom and then finished with mo-type3 that was compacted in lifts. There is also a few other areas that did the same thing. They are in the process of finishin this up. They are going to install concrete instead of asphalt.Steve Robbins 05/14/2018 10:19 AM

Resolved

2 The contractors have finished all the work on the parking lot, they compacted the rock , Olson testing was out checking for compaction. They have poured concrete instead of asphalt. There was 3 or 4 areas around storm drains that they also corrected are now complete.Steve Robbins 05/18/2018 3:15 PM

Comments: