

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20180020, Building Permit - Residential

Address: 409 SE WEISS CIR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	John Benisch	Failed	Monday, May 21, 2018

**Comments:**

- 1. FIRE STOP CHASE BETWEEN GARAGE AND HOUSE**
- 2. MISSING NAIL PLATES ON PLUMBING STACK MAIN FLOOR**
- 3. MISSING HURICANE STAPS ON TRUSSES FIRST FLOOR**
- 4. FIRE STOP MASTER TOILET IN BASEMENT**
- 5. FIRE STOP REC ROOM AT CONCRETE WALL**