

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180020, Building Permit - Residential

Address: 409 SE WEISS CIR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Benisch	Passed	Wednesday, May 23, 2018

Corrective Action Required

1

Corrective Action Required

2

Misc

1. FIRE STOP CHASE BETWEEN GARAGE AND HOUSE
2. MISSING NAIL PLATES ON PLUMBING STACK MAIN FLOOR
3. MISSING HURICANE STAPS ON TRUSSES FIRST FLOOR
4. FIRE STOP MASTER TOILET IN BASEMENT
5. FIRE STOP REC ROOM AT CONCRETE WALL

Comments: