

Temporary Certificate of Occupancy

Permit #: PRRES20173386
Address: 1530 SW BLACKSTONE PL, LEES SUMMIT, MO 64082
Inspected On: Thursday, May 24, 2018
Inspected By: John Benisch
Expiration Date: 12/31/1899 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Benisch	Temporary C of O	Thursday, May 24, 2018

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | 1. BATHROOM FAUCIT IN 1ST BEDROOM ON THE LEFT HAS THE HOT AND COLD WATER ON WRONG SIDE
2. CARPETING MISSING ON STAIRS
3. HANDRAILS LEADING TO 2ND FLOOR NEED TO EXTEND TO THE NOSE OF THE FIRST TREAD |
|---|------|---|