

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20181486, Building Permit - Commercial

Address: 611 SW 3RD ST, Unit:A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Passed	Friday, May 25, 2018

Comments: NO REMAINING ISSUES ON FINAL INSPECTION FOR CHANGE OF OCCUPANT. MAIN LEVEL APPROVED FOR USE AND OCCUPANCY. BASEMENT OK FOR STORAGE USE BUT NOT FOR OCCUPANCY UNTIL UPGRADES ARE IMPLEMENTED PARTICULARLY ON ELECTRICAL WIRING AND DEVICES.

CAUTION REGARDING GLASS IN HAZARDOUS LOCATIONS: GLAZING AT THESE LOCATIONS MUST BE SAFETY GLASS -- TEMPERED OR LAMINATED.

- IN DOORS, SWINGING OR SLIDING**
- IN WALLS WITHIN 24" OF DOOR JAMBS**
- WITHIN 18" OF FLOOR**

SOME SUCH UNITS HAVE NO DISCERNABLE SAFETY ETCHING.