

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20174063,
COLEMAN EQUIPMENT - WATER MAIN EXTENSION
Address: 4101 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

| Inspection: | Inspector: | Outcome: | Date: |
|--|---|-----------------|--------------------------|
| DEI-Water Line - Coliform Test 1 Informational | Jeremy Young | Passed | Tuesday, May 29, 2018 |
| 1 | Jeremy Young 05/29/2018 1:46 PM Contractor has passing bacteria testing for the first day. This is for the main line. | | |
| DEI-Water Line - Coliform Test 2 Informational | Jeremy Young | Passed | Tuesday, May 29, 2018 |
| 1 | Jeremy Young 05/23/2018 2:27 PM Contractor was on site and the 2nd day water samples were pulled. I have run those to the lab for verification and we will wait the test results. | | |
| 2 | Jeremy Young 05/29/2018 1:45 PM Water tests have been concluded for the main line. They have passing tests for the 2nd day testing. | | |

Comments: