

---

**PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

---

Permit #: PRRES20162575, Building Permit - Residential

Address: 304 SE MILL CREEK DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
Driveway Inspection	John DiMauro	Completed with comments	Wednesday, May 30, 2018

Informational

1 John DiMauro 05/30/2018 10:13 AM

The driveway approach cross slope is less than 2.0 percent.

A pre pour inspection was never called in and done on the approach. The sub grade, concrete type and thickness cannot be verified to be correct.

**Comments:**

---