

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161930, Building Permit - Commercial

Address: 813 NW DONOVAN RD, Unit:C1, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	John Borns	Passed	Wednesday, May 30, 2018

Comments: 24" DIAM. PIER HOLES BORED TO FULL 6' DEPTH. REMOVE ALL ROOTS PROTRUDING INTO POUR. OK TO POUR WHEN READY.