

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20172113, Public Works Infrastructure Permit - Commercial

B&B Theatre

Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE-ESC - (Vegetation/Ground Cover) Informational	Steve Robbins	Partial	Thursday, May 31, 2018
1	The vegetation is coming is very well. I am going to let them know they can take down their erosion control.Steve Robbins 05/31/2018 11:08 AM		
DEI-Miscellaneous Inspection	Steve Robbins	Partial	Thursday, May 31, 2018
Corrective Action Required			
1	They have 2 or 3 more area's to finish up in the parking lot where the pavement sunk. There is also 2 panels of sidewalk that need to be replaced in the front of the building that is private.Steve Robbins 05/31/2018 11:16 AM		

Comments: