

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180140, Building Permit - Residential

Address: 1304 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:

Inspector:

Outcome:

Date:

**All Rough Inspection -
Residential**

Khanh Nguyen

Failed

Friday, June 01, 2018

Corrective Action Required

1 Misc

FRAMING:

-Nail cross 2x4 beam to adjacent stud at rear bathroom

-Have engineer address brace wall at rear greatroom corner not per plan

PLUMBING:

-Strap top plates bored more than 50% at exterior walls

***OK TO INSULATE

Comments: