

Temporary Certificate of Occupancy

Permit #: PRCOM20161761
Address: 805 NW DONOVAN RD, LEES SUMMIT, MO 64086
Inspected On: Friday, June 01, 2018
Inspected By: John BornsChristina StantonMichael WeissenbachJohn Borns
Expiration Date: 6/21/2018 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Friday, June 01, 2018

Corrective Action Required:

3 Misc 1ST FLOOR & BASEMENT: CLEAN ALL GLASS AT HAZARDOUS LOCATIONS TO ALLOW "TEMPERED" ETCHING TO BE VERIFIED. SEE GLAZING AT BOTTOM OF STAIRWELLS.

Corrective Action Required:

9 Misc ALSO OBTAIN APPROVAL FROM:
- PLANNING

Occupancy Inspection - Planning	Christina Stanton	Temporary C of O	Friday, June 01, 2018
--	-------------------	------------------	--------------------------

Corrective Action Required:

1 Complete installation of landscaping and sod per approved landscape plan.

Corrective Action Required:

2

Either remove extra ADA space under carport or install required ADA sign for the space.

**Occupancy Inspection -
Fire**

Michael
Weissenbach

Passed

Friday, June 01,
2018