

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20180140, Building Permit - Residential

Address: 1304 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Partial	Monday, June 04, 2018

### Corrective Action Required

1 Misc

#### FRAMING:

-Have engineer address brace wall at rear greatroom corner not per plan

\*\*\*OK TO ROCK

### Comments: