

## **PUBLIC WORKS ENGINEERING DIVISION**

# **Inspection Summary**

Permit #: PRPWFC20172113, Pub	lic Works Infrastrı	ucture Permit -	Commercial
-------------------------------	---------------------	-----------------	------------

**B&B** Theatre

Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:				
Inspection:	Inspector:	Outcome:	Date:	
DEI-Miscellaneous Inspection	Steve Robbins	Partial	Tuesday,	

### Corrective Action Required

They have 2 or 3 more area's to finish up in the parking lot where the pavement sunk.

There is also 2 panels of sidewalk that need to be replaced in the front of the building that is private. Steve Robbins 05/31/2018 11:16 AM

## **Partial Correction**

Today the contractors poured the 2 sections of concrete on the sidewalk that sunk. Steve Robbins 06/01/2018 3:47 PM

#### Resolved

They have corrected all the areas that dropped in the parking lot and on the private sidewalk. Everything has been completed, I told Harold he can take down the silt fence. Now all they need is the As-builts and the bond for the sanitary. Steve Robbins 06/05/2018 3:41 PM

#### **Comments:**