

---

**PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

---

Permit #: PRRES20173335, Building Permit - Residential

Address: 1709 NE PARKWOOD DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Sidewalk Inspection	Jeremy Young	Partial	Friday, June 08, 2018

Informational

- 1 Jeremy Young 06/08/2018 8:55 AM Contractor has formed the sidewalk. They have sufficient compacted rock base. There is a section that is by the mailbox pad that is above 2.0% for ADA. I have informed the contractor to fix these areas.

**Comments:**

---