

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20180775, Building Permit - Commercial

Address: 1196 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Partial	Friday, June 08, 2018

Partial Correction

1	Misc	GAS PIPING PRESSURE TEST HELD STEADY AT >= 20 PSI FOR >=10 MIN..
---	------	--

Corrective Action Required

2	Misc	PROPERLY CLAMP PIPE AT WEST GRILL
---	------	-----------------------------------

Corrective Action Required

3	Misc	IFGC 404.8: METALLIC PIPING EXPOSED TO WEATHER MUST BE PERMANENTLY PROTECTED WITH PAINT OR BY OTHER APPROVED MEANS. PAINT 100% OF STEEL PIPE INCLUDING AT SUPPORTS.
---	------	---

Comments: