Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180570, Building Permit - Residential Address: 1621 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	John Benisch	Passed	Friday, June 08, 2018
Electrical Service Inspection - Residential	John Benisch	Passed	Friday, June 08, 2018
Gas Service Inspection - Residential	John Benisch	Passed	Friday, June 08, 2018
All Rough Inspection - Residential	John Benisch	Failed	Friday, June 08, 2018

Corrective Action Required

1 Misc - need straps at garage portal header

-nail siding at garage portal 3" oc

-fire stop at fir out for duct work in garage- fire stop at heat/ac chase in great room

- fire stop at both ends of fir down above windows in great room

- Install cooler ties as per plan

- flume at furnace needs 6" clearance from combustibles

- verify length of exhaust fan duct in basement bath.

Comments: