

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20174063,
COLEMAN EQUIPMENT - WATER MAIN EXTENSION
Address: 4101 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Coliform Test 1	Jeremy Young	Passed	Friday, June 08, 2018
Informational	1 Jeremy Young 06/05/2018 1:36 PM Crew was on site to pull water samples. We pulled samples and I took them to Blue Valley Labs for analysis.		
Informational	2 Jeremy Young 06/08/2018 11:19 AM Day 1 samples came back good. They were absent for E. Coli and Coliform.		
DEI-Water Line - Coliform Test 2	Jeremy Young	Passed	Friday, June 08, 2018
Informational	1 Jeremy Young 06/06/2018 11:36 AM Contractor has pulled day 2 samples for the BFP/Fire Line. Those were delivered to Blue Valley.		
Informational	2 Jeremy Young 06/08/2018 11:21 AM Day 2 samples were Absent for E. Coli and Coliform. They have passed the testing.		

Comments: