

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20181735, Building Permit - Residential

Address: 1687 NE PARKWOOD DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:

Inspector:

Outcome:

Date:

**Final Building  
Inspection - Residential**

Khanh Nguyen

Passed

Monday, June 11, 2018

Comments: