

## Inspection Summary

Permit #: PRCOM20173222, Building Permit - Commercial  
Address: 4101 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Khanh Nguyen	Failed	Monday, June 11, 2018

### Corrective Action Required

1	Misc	-BOND RACEWAYS ENCLOSING THE SERVICE CONDUCTORS PER 250.92 -CONNECT GROUNDING ELECTRODE CONDUCTOR TO SERVICE GROUNDED CONDUCTOR PER 250.24 -ENCASE THE EXPOSED ROD GROUNDING CLAMPS IN CONCRETE
---	------	---

### Comments: