

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20173808, Building Permit - Residential

Address: 4716 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Jeremy Young	Partial	Tuesday, June 12, 2018

Informational

1 **REINSPECTION FEE ASSESSED.

Informational

2 Jeremy Young 06/12/2018 8:56 AM Contractor has sufficient rock base. He will compact one more time before pouring. There is not a sidewalk on the plot plan for the address. I have informed them to use the KCMMB 4K mix.

Comments: