

Temporary Certificate of Occupancy

Permit #: PRRES20172815
Address: 1813 SW BLACKSTONE PL, LEES SUMMIT, MO 64082
Inspected On: Tuesday, June 12, 2018
Inspected By: John Benisch
Expiration Date: 12/31/1899 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Benisch	Temporary C of O	Tuesday, June 12, 2018

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | 1. MISSING WINDOW CRANK DINNING ROOM
2. MAIN FLOOR TOILET LEAKING
3. HOT AND COLD WATER ON KITCHEN SINK BACKWARDS
4. ADD 2ND LOCK REAR SLIDER
5. REPLACE OUTSIDE FACUCETS
6. REMOVE COVERS ON SMOKE DETECTORS
7. MISSING SCREENS ON WINDOWS
8. HANDRAIL TO SECOND FLOOR SHOULD NOT HAVE AN INTERRUPTION
9. MISSING FAUCETS UPSTAIRS BATHROOMS
10. MISSING VENT COVER MASTER BEDROOM
11. MISSING COVER FRONT OF FURNANCE |
|---|------|---|