

Temporary Certificate of Occupancy

Permit #: PRRES20163192
Address: 1329 NE BRANDYWINE RD, LEES SUMMIT, MO 64064
Inspected On: Tuesday, June 12, 2018
Inspected By: Khanh Nguyen
Expiration Date: 7/12/2018 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Tuesday, June 12, 2018

Corrective Action Required:

- 1 Misc
-COOKTOP: SECURE FLEXIBLE METAL RACEWAY WITHIN 12" OF BOTH THE J-BOX AND COOKTOP TERMINATION ENCLOSURE;
INSTALL LISTED CONNECTOR AT FMC CONNECTION TO COOKTOP J-BOX

-INSTALL BREAKER LOCKS FOR COOKTOP