

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180570, Building Permit - Residential

Address: 1621 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Benisch	Passed	Wednesday, June 13, 2018

Corrective Action Required

1	Misc	<ul style="list-style-type: none">- need straps at garage portal header-nail siding at garage portal 3" oc-fire stop at fir out for duct work in garage- fire stop at heat/ac chase in great room- fire stop at both ends of fir down above windows in great room- Install cooler ties as per plan- flume at furnace needs 6" clearance from combustibles- verify length of exhaust fan duct in basement bath.
---	------	---

Comments: