## **Development Services Department**

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## **Inspection Summary**

Permit #:PRRES20180703, Building Permit - Residential Address: 4415 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date: **All Rough Inspection -** John Benisch Failed Thursday, June 14, 2018 Residential Corrective Action Required Misc 1. FIRESTOP CHASE ABOVE WINDOWS IN FAMILY ROOM 2. FIRESTOP FLUE THAT RUNS TO 2ND FLOOR **Electrical Service** John Benisch Passed Thursday, June 14, 2018 **Inspection - Residential** Gas Piping Inspection - John Benisch Passed Thursday, June 14, 2018 Residential Gas Service Inspection - John Benisch Passed Thursday, June 14, 2018 Residential **Comments:**