

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20180434, Building Permit - Commercial

Address: 2751 NE DOUGLAS ST, Unit:X, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Khanh Nguyen	Partial	Thursday, June 14, 2018

Partial Correction

1	Misc	FRAMING FOR 3HR RATED WALL OK FOR 1ST LAYER GWB BOTH FACES;
---	------	-------------------------------------------------------------

**Comments:**