

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRSITE20180252, Development - Site

TAILOR MADE LANDING

Address: 1600 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Coliform Test 2 Informational	John DiMauro	Partial	Thursday, June 14, 2018
1	John DiMauro 06/14/2018 3:58 PM		

Collected and delivered the day 2 water samples for the fire line to Blue Valley Labs.

DEI-Water Line - Coliform Test 1 Informational	John DiMauro	Passed	Thursday, June 14, 2018
1	John DiMauro 06/14/2018 3:57 PM		

The day 1 samples passed.

Informational
1 John DiMauro 06/13/2018 2:01 PM

The crew collected the day 1 water samples for the fire line. I delivered the samples to Blue Valley Labs. We will know the results from the test tomorrow.

Comments: