

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171951, Building Permit - Residential

Address: 400 SW WATERFALL CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:

Inspector:

Outcome:

Date:

**All Rough Inspection -
Residential**

Mark Harding

Passed

Friday, June 15, 2018

Comments: