

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20181521, Building Permit - Commercial

Address: 697 NW BLUE PKWY, LEES SUMMIT, MO 64086699 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Passed	Friday, June 15, 2018

Comments: UNDER-SLAB DWV PIPING FOR THIS PERMIT IS APPROVED, BUT BRANCH THAT RUNS IN SAME TRENCH COLINEAR WITH THAT FOR ADJACENT PERMIT IS NOT TO BE COVERED UNTIL BOTH ARE APPROVED. PIPE AT RESTROOM ONLY MAY BE COVERED.

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.