
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20180217, Building Permit - Residential

Address: 1300 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Jeremy Young	Partial	Monday, June 18, 2018

Informational

- 1 Jeremy Young 06/18/2018 11:42 AM Contractor has sufficient compacted rock base. They have the expansion joints and will carry less than 2% cross slope for ADA compliance.

Comments:
