

**PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

---

Permit #: PRRES20173808, Building Permit - Residential

Address: 4716 NE POCONO CIR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
Driveway Inspection	Jeremy Young	Passed	Monday, June 18, 2018

Informational

- 1 Jeremy Young 06/18/2018 11:49 AM Contractor has poured the driveway. There is at least 6" of concrete in the ROW approach. They have used the correct mix and the expansion joint is present.

**Comments:**

---