

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173776, Building Permit - Residential

Address: 1713 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Tuesday, June 19, 2018

Corrective Action Required

1	Misc	-FINAL GRADE, SOD, SPLASHBLOCKS -ALL-ROUGH INSPECTION NOT APPROVED -SEAL EXTERIOR LIGHT AT REAR -INSTALL BOX EXTENSIONS AT FLOOR RECEPTACLES -COMPLETE KITCHEN. INSTALL COOKTOP -INSTALL ANTI-BACKFLOW DEVICE FOR THE BASEMENT HOSE BIBB -SECURE WATER SERVICE LINE -SUPPORT GAS PIPING -PROVIDE COMBUSTION AIR OPENINGS PER CODE THE THE WATER HEATER
---	------	--

Comments: