

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20173427, Building Permit - Residential

Address: 1349 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Jeremy Young	Partial	Tuesday, June 19, 2018

Informational

- 1 Jeremy Young 06/19/2018 9:39 AM Contractor has sufficient compacted rock base. They have been instructed to carry less than 2% cross slope for the ADA compliance. The expansion joint is present.

Comments:
