
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20180217, Building Permit - Residential

Address: 1300 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Jeremy Young	Passed	Wednesday, June 20, 2018

Informational

- 1 Jeremy Young 06/20/2018 3:44 PM Contractor has poured the driveway. There is at least 6" of concrete in the ROW approach. They have added the expansion joint and used the correct mix. The cross slope is less than 2% which meets ADA compliance.

Comments:
