

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180854, Building Permit - Residential

Address: 4720 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Khanh Nguyen	Failed	Thursday, June 21, 2018

Corrective Action Required

1	Misc	-SHALL REMOVE ALL LOOSE DIRT FROM BOTTOM OF CORNER PIER
---	------	--

Erosion Control	Khanh Nguyen	Failed	Thursday, June 21, 2018
------------------------	--------------	--------	-------------------------

Corrective Action Required

1	DCM1 Erosion Control	EROSION CONTROL REQUIRED AROUND THE PERMITER OF LOT. RESTORE EROSION CONTROL ALONG THE STREET NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE.
---	----------------------	---

Comments: