
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20173802, Public Works Infrastructure Permit - Commercial
Residences at Echelon
Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Fire Line - Hydrostatic Test Informational	John DiMauro	Passed	Thursday, June 21, 2018
1	John DiMauro 06/21/2018 12:18 PM		

The Kat Excavation crew performed the hydrostatic pressure test on the fire line from the backflow preventer through the entire fire line. I observed the gauge hold at 200 psi for two hours.

Test passed.

Comments:
