Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20180370, Building Permit - Commercial Address: 1704 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Final Building John Borns Partial Friday, June 22, 2018

Inspection - Commercial

Partial Correction

1 Misc NEW/REMODELED SPACES OK FOR USE. TOP OF FIRE WALL TO BE

CLOSED AT NORTH END.

Comments: