

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20173427, Building Permit - Residential

Address: 1349 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Jeremy Young	Failed	Friday, June 22, 2018

Informational

- 1 Jeremy Young 06/22/2018 2:04 PM Contractor has poured the driveway. The finish of the driveway is gouged and peeling due to rain on the finish before cured. I have informed the contractor to replace the approach.

Comments:
