



**LEE'S SUMMIT**  
MISSOURI



## **FIRE DEPARTMENT**

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20170397	Date:	June 25, 2018
Project Title:	RESIDENCES AT ECHELON - BUILDING #1	Applicant:	
Location:	3510 SW HOLLYWOOD DR, Unit:1, LEES SUMMIT, MO 64082	RANGER FIRE INC	1000 S MAIN ST STE 150 GRAPEVINE, TX 76051
Type of Work:		Primary:	(817) 410-9070
Occupancy Group:	R-2		
Description:	NEW 3 STORY APARTMENT BUILDING		

FDTN PERMIT - PRCOM20181560

**\*NOT TO BE ISSUED UNTIL FIRE DEPARTMENT RELEASES PERMIT**

Construction Type: Type VA (1 hour)  
Map Page: 215B

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

**ACTION REQUIRED:(information purposes)**

Field tests and acceptance testing of the system will be required prior to the final occupancy inspection.

Contact the fire department to schedule testing.

(816)969-1300

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**