



PROJECT NAME

Park Ridge 6th Plat

SPECIFICATIONS

Standard Proctor
 ASTM D 698 Method A
 Percent of Compaction N/A
 Moisture Range $\pm\%$ N/A

PROCTOR TEST RESULTS

Max. Dry Density	Optimum Water Content
102.6 pcf	20.9%

ATTERBERG LIMITS (ASTM D-4318)

Liquid Limit	Plastic Limit	Plasticity Index
53	19	34

DESCRIPTION

Brown FAT CLAY

SAMPLE LOCATION

Stockpile at Lot 293



MOISTURE - DENSITY CURVE

Job No.	J030124.09	Test Date	4/2/2017
Sampled By	RFJ	Tested By	DDW
Sample Date	3/28/2018	Calc. By	ADC
Proctor No.	6817	Ch'd By	SCD